



Wiring instructions for Aspen Pumps

Mini Orange      Mini Lime      Mini Aqua      Silent+  
 Univolt          MicroV          Maxi Orange      Maxi Lime      Mini White

**MITSUBISHI 230 VOLT MODELS**

**Models:** MSY-A15NA, MSY-A17NA, MSY-A24NA, MSZ-A09NA, MSZ-A12NA, MSZ-A15NA, MSZ-A17NA, MSZ-A24NA, PCA-A24GA, PCA-A30GA, PCA-A36GA, PCA-A42GA, PKA-A12GA, PKA-A18GA, PKA-A24FA, PKA-A30FGA, PKA-A36FA, PKA-A12GAL, PKA-A18GAL, PKA-A24FAL, PKA-A30FAL, PKA-A36FAL, PLA-A12AA, PLA-A18AA, PLA-A24AA, PLA-A30AA, PLA-A36AA, PLA-A42AA, MSZ-D30NA, MSZ-D36NA, MSY-D30NA, MSY-D36NA, MSZ-D30NA, MSZ-D36NA, MSY-D30NA, MSY-D36NA, MSZ-GA-24NA, MSY-GA24NA

1. Check evaporator voltage to ensure that pump voltage is correct.
2. Install 1 amp inline fuse between evaporator and pump to protect pump and unit.
3. Connect red wire to terminal block in evaporator as shown to ensure pump is powered only when evaporator has power.

**NOTE: DO NOT USE SEPARATE 230 VOLT OUTLET TO POWER PUMP AS THIS IS NOT FAIL SAFE AND MAY CAUSE AN OVERFLOW!**

4. Disconnect wire S1 from terminal S1 in evaporator and reconnect to black power wire of pump and gray common wire of overflow switch with a wire nut as shown. Connect purple wire from switch to terminal S1 in evaporator.

**NOTE: OVERFLOW ALARM WIRE MUST BE CONNECTED TO ENSURE THAT IN CASE OF PUMP FAILURE OR BLOCKAGE IN DISCHARGE HOSE, EVAPORATOR WILL SHUT DOWN. CONNECTION OF THE OVERFLOW ALARM CIRCUIT IS MANDATORY AND FAILURE TO DO SO WILL INVALIDATE PUMP WARRANTY!**

