

## metacaulk<sub>®</sub> SUBMITTAL

Project:	
Architect:	
General Contractor:	
Installing Contractor:	
<u>Distributor (and Contact)</u> :	Manufacturer's Representative:
	<del></del>
	<u> </u>

## APPROVALS FOR METACAULK® PRODUCTS

Below is a list of Model Building Codes requiring the use of firestop products in various types of constructions and occupancies. Most local codes are derived from one or more of these model codes. Metacaulk® products and systems meet the through-penetration firestopping requirements of all of these codes.

ICC . . . . . International Code Council; International Building Code ICBO . . . . . International Code of Building Officials; Uniform Building Code SBCCI . . . . Southern Building Code Congress International; Standard Building Code BOCA . . . . Building Official and Code Administrators International; National Building Code CABO . . . . Council of American Building Officials (coordinating agency between ICBO, SBCCI and BOCA) NBCC . . . . National Building Code of Canada NFPA 101 . . National Fire Protection Association Life Safety Code IRC . . . . . International Residence Code

Certain cities, counties and states have written their own code requirements which may supersede or supplement model building codes, check with these authorities for approvals.

Metacaulk® Products are UL Classified and conform to the codes and test requirements shown below.

UL 1479 . . . . Fire Tests of Through-Penetration Firestops UL 2079 . . . . Tests for Fire Resistance of Building Joint Systems ASTM E 1966 . . . . . Standard Test Method for Fire Resistive Joint Systems ASTM E 814 . . . . . Methods for Fire Tests of Through-Penetration Fire Stops NFPA 101 . . . . . National Fire Protection Association Life Safety Code ASTM E 84 (UL 723) . Test Method for Surface Burning Characteristics of Building Materials ASTM E 119 (UL 263) . Method for Fire Tests of Building Construction and Materials

ULC CAN4-S115M... Standard Method of Fire Tests of Firestop Systems B.S. 476/ pr EN 1366.3. European/ British Standards

AS 1530.4 . . . . . Part 4: Fire Resistance Tests of Elements of Building Construction

AS 4072.1 . . . . . Part 1: Service Penetration and Control Joint